



CARSON 1220-4B 'T' TYPE LID:
 SHALL INCLUDE STRAIGHT TYPE HEXAGON LOCK-DOWN BOLT (1) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

CHRISTY FL30T RECESSED LID:
 SHALL INCLUDE STRAIGHT TYPE PENTAHEAD LOCK-DOWN BOLTS (2) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

METER YOKE:
 FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	9	1" COPPER/BRASS METER YOKE - 12" HEIGHT w/2 FULL PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	10	3/4" WATER METER (BY DISTRICT)	
3	1" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SODR 9 (250 PSI) OR EQUAL	11	1" x 3/4" METER ADAPTORS (BY DISTRICT)	
4	1" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	12	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)	
5	1" BRASS STREET ELBOW	13	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)	
6	1" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	14	1" PVC COUPLING - SCH 80	
7	1" BRASS NIPPLE (AS NECESSARY TO ADJUST TO PROPER GRADE)		NON-Traffic AREAS	Traffic AREAS
8	1" DUAL PURPOSE CONNECTION	15	METER BOX	CARSON 1220-12
		16	LID	CARSON 1220-4B
		17	2" x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)	
		18	3/4" CLEAN CRUSHED ROCK	
		19	#2 WASHED SAND COMPACTED TO 90%	
		20	#10 INSULATED COPPER LOCATOR WIRE	



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

**1" POLYETHYLENE WATER SERVICE - 3/4" WATER METER
 NEW CONSTRUCTION**

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Chubille

CITRUS HEIGHTS WATER DISTRICT

DATE: 9/25/14

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_076PE.DWG

PAGE:

WS_076PE