



**CARSON 1220-4B "T" TYPE LID:**

SHALL INCLUDE STRAIGHT TYPE HEXAGON LOCK-DOWN BOLT (1) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

**CHRISTY FL30T RECESSED LID:**

SHALL INCLUDE STRAIGHT TYPE PENTAHEAD LOCK-DOWN BOLTS (2) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

**METER YOKE:**

FORD, JONES, MUELLER, McDONALD

1	1' BRONZE SADDLE - IPT	10	1' WATER METER (BY DISTRICT)
2	1' CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	11	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)
3	1' COPPER TUBING - TYPE K SOFT	12	1' x 18' PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
4	1' BRASS STREET ELBOW - CTS COMP x MIP	13	1' PVC COUPLING - SCH 80
5	1' BRASS STREET ELBOW		NON-TRAFFIC AREAS
6	1' VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP	14	METER BOX
7	1' BRASS or COPPER (AS NECESSARY TO ADJUST TO PROPER GRADE)	15	LID
8	1' DUAL PURPOSE CONNECTION	16	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
9	1' COPPER/BRASS METER YOKE - 12' HEIGHT w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	17	3/4" CLEAN CRUSHED ROCK
		18	#2 WASHED SAND COMPACTED TO 90%

**1" COPPER WATER SERVICE - 1" WATER METER  
NEW CONSTRUCTION**

**CITRUS HEIGHTS WATER DISTRICT**



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

APPROVED BY:

*Robert A. Churchill*

DATE: 9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS\_100CU.DWG

PAGE:

**WS\_100CU**