



**CARSON 1220-4B "T" TYPE LID:**  
 SHALL INCLUDE STRAIGHT TYPE HEXAGON  
 LOCK-DOWN BOLT (1) AND TOUCH READ HOLE.  
 SHALL BE MARKED "WATER"

**CHRISTY FL30T RECESSED LID:**  
 SHALL INCLUDE STRAIGHT TYPE PENTAHEAD  
 LOCK-DOWN BOLTS (2) AND TOUCH READ HOLE.  
 SHALL BE MARKED "WATER"

**METER YOKE:**  
 FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	9	1" COPPER/BRASS METER YOKE - 12" HEIGHT w/2 FULL PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	10	1" WATER METER (BY DISTRICT)	
3	1" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SODR 9 (250 PSI) OR EQUAL	11	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)	
4	1" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	12	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)	
5	1" BRASS STREET ELBOW	13	1" PVC COUPLING - SCH 80	
6	1" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)			
7	1" BRASS NIPPLE (AS NECESSARY TO ADJUST TO PROPER GRADE)		NON-TRAFFIC AREAS	TRAFFIC AREAS
8	1" DUAL PURPOSE CONNECTION	14	METER BOX	CARSON 1220-12
		15	LID	CARSON 1220-4B
		16	2" x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)	
		17	3/4" CLEAN CRUSHED ROCK	
		18	#2 WASHED SAND COMPACTED TO 90%	
		19	#10 INSULATED COPPER LOCATOR WIRE	

**1" POLYETHYLENE WATER SERVICE - 1" WATER METER  
 NEW CONSTRUCTION**

**CITRUS HEIGHTS WATER DISTRICT**



**CITRUS  
 HEIGHTS  
 WATER  
 DISTRICT**

APPROVED BY: Robert A. Chubice DATE: 9/25/14  
 CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014  
 REVISED:  
 SCALE: N.T.S.  
 DESIGN: P.A.D.  
 CAD FILE: WS\_100PE.DWG  
 PAGE: **WS\_100PE**