



1	1" BRONZE SADDLE - IPT	5	1" VALVE - FULL-PORT BALL, FIP x FIP or CTS x FIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	6	1" BRASS STREET ELBOW
3	1" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SODR 9 (250 PSI) OR EQUAL	7	#2 WASHED SAND COMPACTED TO 90%
4	1" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52)	8	#10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX)



**CITRUS
HEIGHTS
WATER
DISTRICT**

1" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE:

9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_108PE.DWG

PAGE:

WS_108PE