



| | | | |
|---|---|---|---|
| 1 | 1' BRONZE SADDLE - IPT | 4 | 1' BRASS COUPLING AS REQUIRED TO CONNECT TO EXISTING 1' WATER SERVICE |
| 2 | 1' CORPORATION STOP - FULL-PORT BALL, MIP xCTS COMP | 5 | #2 WASHED SAND COMPACTED TO 90% |
| 3 | 1' COPPER TUBING - TYPE K SOFT | | |



**CITRUS
HEIGHTS
WATER
DISTRICT**

1" COPPER WATER SERVICE SADDLE REPLACEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE: 9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_109CU.DWG

PAGE:

WS_109CU