



1	1' BRONZE SADDLE - IPT	4	1' BRASS COUPLING AS REQUIRED TO CONNECT TO EXISTING 1' WATER SERVICE w/ STAINLESS STEEL INSERT (1' CTS INSERT-52)
2	1' CORPORATION STOP - FULL-PORT BALL, MIP xCTS COMP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52)	5	#2 WASHED SAND COMPACTED TO 90%
3	1' POLYETHYLENE TUBING - CTS ENDPORE PE-4710 SODR 9 (250 PSI) OR EQUAL	6	#10 INSULATED COPPER LOCATOR WIRE



**CITRUS
HEIGHTS
WATER
DISTRICT**

1" POLYETHYLENE WATER SERVICE SADDLE REPLACEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE:

9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_109PE.DWG

PAGE:

WS_109PE