



1	1' BRONZE SADDLE - IPT	5	1' VALVE - FULL-PORT BALL, FIP x FIP or IPS COMP x FIP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52)
2	1' CORPORATION STOP - FULL-PORT BALL, MIP x IPS COMP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52)	6	1' BRASS STREET ELBOW
3	1 1/4' POLYETHYLENE TUBING - CTS ENDPORRE PE-4710 SDDR 9 (250 PSI) OR EQUAL	7	#2 WASHED SAND COMPACTED TO 90%
4	1' BRASS STREET ELBOW - IPS COMP x MIP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52)	8	#10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX)



**CITRUS
HEIGHTS
WATER
DISTRICT**

1 1/4" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE: 9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_128PE.DWG

PAGE:

WS_128PE