



1	1 1/2' BRONZE SADDLE - IPT	5	1 1/2' VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (1 1/2' CTS INSERT-54-Q)
2	1 1/2' CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (1 1/2' CTS INSERT-54-Q)	6	1 1/2' BRASS STREET ELBOW
3	1 1/2' POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SODR 9 (250 PSI) OR EQUAL	7	#2 WASHED SAND COMPACTED TO 90%
4	1 1/2' BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (1 1/2' CTS INSERT-54-Q)	8	#10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX)



**CITRUS
HEIGHTS
WATER
DISTRICT**

1 1/2" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: Robert A. Churchill DATE: 9/25/14
CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014
REVISED:
SCALE: N.T.S.
DESIGN: P.A.D.
CAD FILE: WS_158PE.DWG
PAGE: **WS_158PE**