



NOTES:

1. VOIDS AROUND THE WATER MAIN AT THE ENTRY AND EXIT POINTS FROM THE METER BOX SHALL BE COMPLETELY GROUTED WITH MORTAR MIX.
2. LID SHALL BE MARKED "WATER"

1	2" BRONZE SADDLE - IPT	11	2" STRAINER - NEPTUNE 53107-000 (BY CONTRACTOR)
2	2" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	12	2" COMPOUND WATER METER, NEPTUNE TRU/FLO, 100 cu. ft., (BY CONTRACTOR)
3	2" COPPER TUBING - TYPE K SOFT		
4	2" BRASS STREET ELBOW - CTS COMP x MIP		
5	2" BRASS STREET ELBOW	13	METER BOX
6	2" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP	14	COVER
7	2" BRASS (AS NECESSARY TO ADJUST TO PROPER GRADE)	15	BOX EXTENSION
8	2" BRASS ELBOW	16	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
9	2" x 12" BRASS NIPPLE	17	3/4" CLEAN CRUSHED ROCK
10	2" BALL VALVE - FIP x METER FLANGE INCLUDING PADLOCK WINGS	18	#2 WASHED SAND COMPACTED TO 90%



**CITRUS
HEIGHTS
WATER
DISTRICT**

**2" COPPER WATER SERVICE - 2" COMPOUND WATER METER
NEW CONSTRUCTION**

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE:

9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_202CU.DWG

PAGE:

WS_202CU