



# 2015 CONSUMER CONFIDENCE REPORT



This report is published by the San Juan Wholesale Customer Agencies: San Juan Water District, Citrus Heights Water District, Fair Oaks Water District and Orange Vale Water District. San Juan Water District provides reliable, high-quality water supplies to our customers. We serve nearly 184,000 customers in our retail and wholesale service areas throughout Sacramento and Placer counties. We test our surface water, which comes from the American River watershed, and our local groundwater for microbiological and chemical quality.

The U.S. Environmental Protection Agency and the State Water Resources Control Board maintain strict water quality standards designed to protect customers from waterborne disease organisms and harmful chemicals. As a public water agency, we are required by the USEPA to provide you with an annual Consumer Confidence Report.

This report provides you with information about drinking water quality and how we comply with drinking water quality standards. As your water provider, we are proud to report this year's CCR concludes that, once again, your drinking water meets all federal and state drinking water standards.

## WHAT'S IN YOUR WATER?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in the source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

## WHERE DOES YOUR WATER COME FROM?

Water from the Agencies comes from two sources: treated surface water and groundwater. San Juan Water District diverts and treats surface water from Folsom Lake. This treated water is then distributed to the Agencies. Orange Vale Water Company and San Juan Water District receive 100 percent of their supply from treated surface water. If you are a consumer of Citrus Heights or Fair Oaks water districts, your water is a mixture of treated surface water from San Juan Water District and groundwater from local wells.

**San Juan Water District** – 100% surface water  
**Orange Vale Water Company** – 100% surface water  
**Citrus Heights Water District** – 91.6% surface water, 8.4% groundwater  
**Fair Oaks Water District** – 89.3% surface water, 10.7% groundwater

Source water assessments have been conducted for all the water sources to enable the Agencies to understand the activities that have the greatest potential for contaminating the drinking water supplies. The groundwater sources were assessed in 2002 and the surface water source was evaluated in 2001. New wells for Citrus Heights Water District were assessed in 2008 and 2009. These assessments were conducted in accordance with State Board guidelines and copies of

the complete assessments are available for review at the respective agency offices.

San Juan Water District conducted the evaluation of the Folsom Lake source. It was found to be most vulnerable to potential contamination from the Folsom Lake State Recreation Area facilities, high-density housing and associated activities such as sewer and septic systems and fertilizer, pesticide and herbicide application, as well as illegal activities and dumping. The source water is typically treated using conventional treatment with filtration and disinfection that is designed to remove many contaminants. Again this year, your water meets all federal and state drinking water standards.

Citrus Heights and Fair Oaks water districts conducted assessments of their local groundwater wells. It was found that all the wells are vulnerable to commercial urban activities, such as active and historic gas stations, dry cleaners, leaking underground storage tanks, known contaminant plumes, automobile repair shops, and sewer collection systems, none of which are associated with any detected contaminants.

Although Orange Vale Water Company does not currently utilize available local groundwater, assessments found that wells within their service area would be most vulnerable to rural grazing activities.

## A NOTE FOR SENSITIVE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

## GENERAL INFORMATION ON LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The San Juan Family Agencies are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The San Juan Family Agencies test selected customer taps every three years for lead and over ninety-five percent of samples are non-detectable and therefore not reported in the data table.

## UNREGULATED CONTAMINANT MONITORING RULE (UCMR3) RESULTS

USEPA requires public water systems to collect data for unregulated constituents in drinking water supplies under the Unregulated Contaminant Monitoring Rule 3. Currently, these constituents have no drinking water standards but may be regulated in the future. More information on this USEPA program can be found at <http://water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/ucmr3/index.cfm>. Citrus Heights Water District and Fair Oaks Water District conducted sampling in 2014. Orange Vale Water Company and San Juan Water District conducted sampling in 2015. Several constituents were detected, none at any level of human health concern.

CONSTITUENT	Range (ug/L)	Average (ug/L)	Human Health Advisory	Potential Sources
<b>HCFC-22 (chlorodifluoromethane)</b>	ND-0.11 <sup>1</sup>	ND <sup>1</sup>	None	Refrigerant and propellant
<b>Vanadium</b>	1.1-11 <sup>1</sup>	7.2 <sup>1</sup>	State Board Notification Level – 50 ug/L	Naturally-occurring metal
	0.52-8.1 <sup>2</sup>	3.4 <sup>2</sup>		
	0.47-1.0 <sup>3</sup>	0.67 <sup>3</sup>		
	0.63-1.2 <sup>4</sup>	1 <sup>4</sup>		
<b>Molybdenum</b>	ND-1 <sup>1</sup>	ND <sup>1,2</sup>	USEPA Lifetime Health Advisory – 40 ug/L	Naturally-occurring metal
	ND-1.7 <sup>2</sup>			
<b>Strontium</b>	46-460 <sup>1</sup>	245 <sup>1</sup>	USEPA Lifetime Health Advisory – 4,000 ug/L	Naturally-occurring metal
	46-220 <sup>2</sup>	120 <sup>2</sup>		
	52-64 <sup>3</sup>	59.8 <sup>3</sup>		
	46-59 <sup>4</sup>	53 <sup>4</sup>		
<b>Chlorate</b>	ND-40 <sup>1</sup>	ND <sup>1</sup>	State Board Notification Level – 800 ug/L	Oxidant used in pyrotechnics and possible by-product of water treatment
	ND-240 <sup>2</sup>	37 <sup>2</sup>		
<b>Testosterone</b>	ND-0.00013 <sup>1</sup>	ND <sup>1</sup>	None	Mammalian hormone

1 – Citrus Heights Water District (wells, treated surface water from SJWD, and distribution system - 2014)

2 – Fair Oaks Water District (wells, treated surface water from SJWD, and distribution system - 2014)

3 – SJWD (treated surface water and distribution system - 2015)

4 – Orange Vale Water Company (treated surface water from SJWD and distribution system - 2015)

## KEY TO ABBREVIATIONS

PPB	parts per billion or micrograms per liter (µg/L)
PPM	parts per million or milligrams per liter (mg/L)
NTU	nephelometric turbidity units
µS/CM	microsiemens per centimeter
ND	not detected
NR	not required
N/A	not applicable
TON	threshold odor number

## WATER QUALITY DEFINITIONS

**Maximum Contaminant Level (MCL)** — The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Public Health Goal (PHG)** — The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG)** — The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL)** — The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** — The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standard (PDWS)** — MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Treatment Technique (TT)** — A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL)** — The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Notification Level (NL)** — Health-based advisory level set by the State Board for constituents with no MCL. This is not an enforceable standard, although requirements and recommendations may apply if detected above this level.

# SAN JUAN WHOLESale CUSTOMER AGENCIES – 2015 TABLE OF DETECTED CONSTITUENTS

DETECTED PRIMARY DRINKING WATER CONSTITUENTS regulated to protect your health															
CONSTITUENT	UNITS	PHG or (MCLG) or (MRDLG)	MCL or (MRDL)	San Juan Surface Water Including Orange Vale Water Company(a)			Citrus Heights Groundwater			Fair Oaks Groundwater			MAJOR SOURCES		
				RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED			
Arsenic	PPB	0.004	10	ND	ND	2013	ND-3.7	ND	2013	ND - 2.2	ND	2006, 2012	Erosion of natural deposits; runoff from orchards; glass and electronics production waste		
Barium	PPM	2	1	ND	ND	2013	ND-0.1	ND	2013	ND	ND	2006, 2012	Erosion of natural deposits and wastes from metal refineries		
Fluoride	PPM	1	2.0	ND	ND	2013	ND-0.18	0.12	2013	ND - 0.11	ND	2006, 2012	Erosion of natural deposits; discharge from fertilizer and aluminum factories		
Hexavalent Chromium	PPB	0.02	10	ND	ND	2015	ND-2.3	1.4	2014	ND-2.5	ND	2014	Erosion from natural deposits or discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities		
Nitrate (as N)	PPM	10	10	ND	ND	2015	1.2 - 2.9	1.8	2014	ND - 0.5	0.5	2007, 2015	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits		
Chlorine Residual (distribution system)	PPM	[4]	[4]	0.16-0.82 (0.15-0.89)	0.53 (0.5)	2015	0.22-0.8	0.54	2015	0.2 - 1.08	0.48	2015	Drinking water disinfectant added for treatment		
Total Trihalomethanes (distribution system)	PPB	N/A	80	43-60 (33-61)	48.5 (47)	2015	ND-54	42	2015	ND-48	17.0	2015	By-product of drinking water disinfection		
Haloacetic Acids (distribution system)	PPB	N/A	60	19-26 (19-30)	23.5 (24.5)	2015	ND-38	27	2015	ND-26	8.0	2015	By-product of drinking water disinfection		
Control of Disinfection By-Product Precursors (TOC) (treated water) (b)	PPM	N/A	TT = 2	1.1-3.2	1.3	2015	NR	N/A	N/A	NR	N/A	N/A	Various natural and manmade sources		
CONSTITUENT	UNITS	PHG or (MCLG)	MCL	LEVEL FOUND			YEAR SAMPLED			LEVEL FOUND			YEAR SAMPLED		MAJOR SOURCES
Turbidity (b)	NTU	N/A	TT = 1 NTU	0.035			2015			NR			N/A		Soil runoff
	% Samples	N/A	TT = ≤0.3 NTU	100			2015			NR			N/A		
	UNITS	PHG or (MCLG)	AL	90th PERCENTILE	# SAMPLED/ # EXCEED AL	YEAR SAMPLED	90th PERCENTILE	# SAMPLED/ # EXCEED AL	YEAR SAMPLED	90th PERCENTILE	# SAMPLED/ # EXCEED AL	YEAR SAMPLED	MAJOR SOURCES		
Copper	PPM	0.3	1.3	0.072 (0.076)	30/0 (31/0)	2015 (2015)	0.074	30/0	2015	0.054	30/0	2013	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives		
DETECTED SECONDARY DRINKING WATER CONSTITUENTS regulated for aesthetic qualities															
CONSTITUENT	UNITS	PHG or (MCLG)	MCL	San Juan Surface Water including Orange Vale Water Company			Citrus Heights Groundwater			Fair Oaks Groundwater			MAJOR SOURCES		
				RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED			
Total Dissolved Solids	PPM	N/A	1,000	41	41	2013	190-260	228	2013	100-400	181	2006, 2012	Runoff/leaching from natural deposits		
Specific Conductance	µS/CM	N/A	1,600	58-84	72	2013	260-350	294	2013	140-550	263	2006, 2012	Substances that form ions when in water		
Sulfate	PPM	N/A	500	4.8	4.8	2013	7.8-12	9.7	2013	3.6-28	10.8	2006, 2012	Runoff/leaching from natural deposits		
Chloride	PPM	N/A	500	2.8	2.8	2013	10-18	15	2013	3.1-23	6.9	2006, 2012	Runoff/leaching from natural deposits		
Turbidity	NTU	N/A	5	0.017-0.035	0.025	2015	ND-0.1	ND	2013	0.12-0.6	0.35	2006, 2012	Soil runoff		
Odor	TON	N/A	3	2	2	2013	ND	ND	2013	ND	ND	2006, 2012	Naturally-occurring organic materials		
DETECTED UNREGULATED DRINKING WATER CONSTITUENTS (c)															
CONSTITUENT	UNITS	PHG or (MCLG)	NL	San Juan Surface Water Including Orange Vale Water Company			Citrus Heights Groundwater			Fair Oaks Groundwater			MAJOR SOURCES		
				RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED	RANGE	AVERAGE	YEAR SAMPLED			
Hardness	PPM	N/A	NONE	20	20	2013	95-150	121	2013	47-210	86.8	2006, 2012	Hardness is the sum of polyvalent cations present in the water, generally naturally occurring magnesium and calcium.		
Sodium	PPM	N/A	NONE	2.5	2.5	2013	11-23	18.8	2013	4.9-32	11.6	2006, 2012	Naturally occurring salt in the water		
Calcium	PPM	N/A	NONE	5.2	5.2	2013	23-33	27	2013	12-43	19.6	2006, 2012	Erosion of natural deposits		
Magnesium	PPM	N/A	NONE	1.7	1.7	2013	9.4-16	12.7	2013	4.2-25	9.2	2006, 2012	Erosion of natural deposits		

(a)– Data for OVWC Distribution System is shown in parenthesis.

(b)– Only surface water sources must comply with PDWS for Control of Disinfection By-Product Precursors and turbidity.

(c)– Unregulated contaminant monitoring helps determine where certain contaminants occur and whether they need to be regulated.

The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Some of our data, though representative, are more than one year old.



## 2015 CONSUMER CONFIDENCE REPORT

### San Juan Wholesale Customer Agencies

P.O. Box 2157  
Granite Bay, CA 95746

#### Board of Directors

Edward J. "Ted" Costa  
Kenneth H. Miller  
Dan Rich  
Pamela Tobin  
Bob Walters

*Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.*

# Your drinking water continues to meet all state and federal drinking water standards.



## CONTACT US

If you have any questions about this report or your water supply, please contact your local water provider. Each of the member agencies holds monthly board meetings that are open to the public as indicated below.



### San Juan Water District

Contact Person:  
Greg Turner  
(916) 791-1715  
gturner@sjwd.org  
www.sjwd.org

Board Meetings:  
2nd and 4th Wednesday  
each month  
7:00 p.m.  
9935 Auburn-Folsom Road  
Granite Bay

### Citrus Heights Water District

Contact Person:  
Brian Hensley  
(916) 725-6873  
bhensley@chwd.org  
www.chwd.org

Board Meetings:  
2nd Tuesday each month  
6:30 p.m.  
6230 Sylvan Road  
Citrus Heights

### Fair Oaks Water District

Contact Person:  
Michael Nisenboym, P.E.  
(916) 844-3513  
mnisenboym@fowd.com  
www.fowd.com

Board Meetings:  
2nd Monday every month  
6:30 p.m.  
10326 Fair Oaks Boulevard  
Fair Oaks

### Orange Vale Water Company

Contact Person:  
Mark DuBose  
(916) 988-1693  
mdubose@orangevalewater.com  
www.orangevalewater.com

Board Meetings:  
1st Tuesday each month  
5:00 p.m.  
9031 Central Avenue  
Orangevale

# LEARN MORE ABOUT YOUR WATER AT [WWW.SJWD.ORG](http://WWW.SJWD.ORG)