

NOTES

- REDUCED PRESSURE BACKFLOW PREVENTION ASSEMBLY SHALL BE PLUMB.
- CONTACT CITRUS HEIGHTS WATER DISTRICT FOR REBAR INSPECTION PRIOR TO POURING CONCRETE, (916) 725-6873
- MATERIAL BELOW AGGREGATE BASE SHALL BE COMPACTED TO 90% MINIMUM.
- REINFORCED CONCRETE PAD SHALL BE FINISHED WITH AN EDGING TOOL AROUND THE ENTIRE PERIMETER AND BROOMED AT RIGHT ANGLES TO THE DIRECTION OF TRAFFIC.
- RPA SHALL BE TESTED BY A CHWD CERTIFIED BACKFLOW PREVENTION ASSEMBLY TESTER PRIOR TO DISTRICT ACCEPTANCE OF FACILITIES.
- COLOR OF WEATHER FREEZE BAG TO BE DETERMINED BY DISTRICT INSPECTOR.

| - | 2 | BRASS ELBOW BRASS NIPPLE - CONTINUOUS | 11 | WEATHER FREEZE BAG - POLAR BAG w/ CALLIDPE FABRIC (8-YEAR WARRANTY), CONTACT ROSEVILLE AUTO UPHOLSTRY. |
|----------|----|---|----|---|
| \vdash | | | | |
| | 3 | Brass union | 12 | REINFORCED CONCRETE PAD - TYPE II SIX-SACK PORTLAND CEMENT - SEE ABOVE NOTE FOR PAD SIZE |
| 4 | 4 | 3' OR 4' BRASS NIPPLE | | |
| | 5 | BRASS STREET ELBOW | 13 | 3/8" (#3) REBAR - 2" INSIDE PERIMETER |
| | 6 | WYE STRAINER - BRONZE W/ PLUG | 14 | CONCRETE DOBIE w/WIRE |
| | 7 | CLOSE BRASS NIPPLE | 15 | 3' PVC SLEEVES - SAND FILLED |
| | 8 | REDUCED PRESSURE BACKFLOW PREVENTION ASSEMBLY W/ BALL VALVES and TEST COCKS W/ BRASS PLUGS (4) - SEE ABOVE NOTE FOR FURTHER INFORMATION 24' BRASS NIPPLE | 16 | 3/4" CLASS 2 AGGREGATE BASE - 2" MINIMUM, MECHANICALLY COMPACTED TO 90% |
| | | | 17 | PRESSURE REGULATOR - AS DETERMINED BY THE APPROPRIATE GOVERNING AUTHORITY |
| | 9 | | | |
| | 10 | PVC COUPLING - SCH 80, THREADED | | |



3/4" TO 2" REDUCED PRESSURE BACKFLOW PREVENTION ASSEMBLY w/ WEATHER FREEZE BAG

| CITRUS HEIGHTS WATER DISTRICT | T DRAWN 8 MAY 2013 |
|--------------------------------|---------------------|
| CITROS HEIGITIS WATER DISTRICT | REVISED |
| APPRIIVED BY: | SCALE: N.T.S. |
| Polet a . Chilia DATE 5/8/13 | DESIGN: P.A.D. |
| CITRUS HEIGHTS WATER DISTRICT | CAD FILE:RP_311.DWG |
| | PAGE: RP_311 |