



MAIN DIAMETER	MINIMUM TRENCH WIDTH
4"	18"
6"	24"
8"	24"
10"	30"
12"	30"

4" THROUGH 12" TRENCH DETAIL - SHOULDER

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

APPROVED BY:

Robert A. Chubb

DATE: 5/8/13

SCALE: N.T.S.

DESIGN: P.A.D.

CITRUS HEIGHTS WATER DISTRICT

CAD FILE: TREN_712.DWG

PAGE:

TREN_712



CITRUS
HEIGHTS
WATER
DISTRICT