



NOTES:

1. SLURRY SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS WITHIN COUNTY OF PLACER RIGHT-OF-WAY ONLY.
2. IF $X < 3$ FT. FOR ALL TRENCHES REPAVE TO EDGE OF PAVEMENT. IF $X < 5$ FT. SEAL TO EDGE OF PAVEMENT.
3. PAVEMENT SAWCUT SHALL BE LOCATED OUTSIDE OF VEHICLE WHEEL PATH.

MAIN DIAMETER	MINIMUM TRENCH WIDTH
4"	18"
6"	24"
8"	24"
10"	30"
12"	30"



**CITRUS
HEIGHTS
WATER
DISTRICT**

4" THROUGH 12" TRENCH DETAIL - PAVEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:
Robert A. Chumbley

DATE: 5/8/13

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN_713PC.DWG

PAGE:

TREN_713PC

FOR CONSTRUCTION IN THE COUNTY OF PLACER