



**NOTES:**

1. NO PAVEMENT CUTS OR TRENCHES ARE ALLOWED IN PAVEMENT LESS THAN THREE YEARS OLD, UNLESS APPROVED BY THE COUNTY OF SACRAMENTO.
2. 1 1/2' DEEP GRINDING AND PAVING. GRIND TO LIP OF GUTTER, LANE LINE, OR CENTER OF TRAFFIC LANE, BUT 12' MINIMUM WIDTH.
3. SLURRY SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS SPECIFIED, AS SHOWN ON THE PLANS OR AS DIRECTED BY THE COUNTY OF SACRAMENTO.
4. STREET STRUCTURAL SECTION PER COUNTY OF SACRAMENTO STANDARDS.

MAIN DIAMETER	MINIMUM TRENCH WIDTH
4'	18'
6'	24'
8'	24'
10'	30'
12'	30'



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

# 4" THROUGH 12" TRENCH DETAIL - PAVEMENT

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY: Robert A. Chubb DATE: 5/8/13  
CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013  
REVISED:  
SCALE: N.T.S.  
DESIGN: P.A.D.  
CAD FILE: TREN\_713SC.DWG

**FOR CONSTRUCTION IN THE COUNTY OF SACRAMENTO**

PAGE: **TREN\_713SC**