



MAIN DIAMETER	MINIMUM TRENCH WIDTH
14"	30"
16"	30"
18"	36"
24"	36"



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

14" THROUGH 24" TRENCH DETAIL - SHOULDER

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: *Robert A. Campbell*

DATE: *5/8/13*

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN_716.DWG

PAGE:

TREN_716