



NOTES:

1. SLURRY SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS WITHIN COUNTY OF PLACER RIGHT-OF-WAY ONLY.
2. IF X < 3FT. FOR ALL TRENCHES REPAVE TO EDGE OF PAVEMENT. IF X < 5FT. SEAL TO EDGE OF PAVEMENT.
3. PAVEMENT SAWCUT SHALL BE LOCATED OUTSIDE OF VEHICLE WHEEL PATH.

MAIN DIAMETER	MINIMUM TRENCH WIDTH
14'	30'
16'	30'
18'	36'
24'	36'



**CITRUS
HEIGHTS
WATER
DISTRICT**

14" THROUGH 24" TRENCH DETAIL - PAVEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: Robert A. Chudler DATE: 5/8/13
CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013
REVISED:
SCALE: N.T.S.
DESIGN: P.A.D.
CAD FILE: TREN_717PC.DWG

FOR CONSTRUCTION IN THE COUNTY OF PLACER

PAGE:
TREN_717PC