



NOTE:

1. AN 18 FOOT LENGTH OF PC350 DUCTILE IRON PIPE (DIP) OR A 20 FOOT LENGTH OF CL305 OR 14 AWWA C900-07 POLYVINYLCHLORIDE (PVC) WATER MAIN TO BE CENTERED BELOW SEWER OR STORM DRAIN CROSSINGS.



SEWER/STORM CROSSING DETAIL

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:
Robert A. Chumbley
 CITRUS HEIGHTS WATER DISTRICT

DATE: *5/8/13*

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN_782.DWG

PAGE:

TREN_782