



NOTES:

1. NO WATER MAINS PARALLEL TO SEWERS OR STORM DRAINS SHALL BE CONSTRUCTED IN THIS ZONE WITHOUT PRIOR WRITTEN APPROVAL FROM THE CALIFORNIA DEPARTMENT OF PUBLIC HEALTH.
2. WATER MAINS IN THIS ZONE SHALL BE CONSTRUCTED OF PC350 DUCTILE IRON PIPE (DIP) OR CL305 DR 14 AWWA C900-07 POLYVINYLCHLORIDE (PVC).



**CITRUS
HEIGHTS
WATER
DISTRICT**

SEWER/STORM PARALLEL DETAIL

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Chubb

DATE: 5/8/13

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN_783.DWG

PAGE:

TREN_783