

COMMERCIAL DEVELOPMENT WATER SYSTEM NOTES

May 8, 2013

CHWD in CITY OF ROSEVILLE FIRE DEPARTMENT

- F-1. Contact the City of Roseville Fire Department Fire Prevention Bureau (Phone (916) 774-5800) and the Citrus Heights Water District (Phone (916) 725-6873) prior to the installation of fire hydrants and upon storage of combustible materials on site.
- F-2. Fire hydrants shall be Clow 2060 or James Jones J3762-231 and a minimum bury length of forty-eight inches (48") with a mechanical joint inlet.
- F-3. Fire hydrants to be located as shown on the plan as approved by the Fire Department with the 4½-inch outlet rotated toward the traffic lane unless otherwise specified. Fire hydrants shall be installed two inches (2") from the bottom of the bury flange and twenty-eight inches (28") maximum from the centerline of the 4½-inch outlet above finish grade. Fire hydrants shall be placed between eighteen inches (18") minimum to twenty-four inches (24") maximum behind the sidewalk or planter curb to centerline.
- F-4. There shall be no obstructions, including plants, within a thirty-six inch (36") radius of any fire hydrant. There shall be a seven foot (7') vertical clearance above the thirty-six inch (36") clear radius around any fire hydrant. Concrete access pads are required to be installed around all fire hydrants unless otherwise specified by the Plans or Detail Drawings.
- F-5. Fire hydrants and protection barricades, when required, shall be cleaned of all loose debris and painted using a manufacturer's recommended primer coat and finished with a minimum of two (2) coats of Rustoleum Gloss White enamel.
- F-6. Pressure sensitive blue marker shall be installed for fire hydrants to Fire Department specifications.
- F-7. All fire hydrants shall be installed prior to any construction or storage of combustible materials on the site. The hydrants shall be accessible via an all-weather driving surface, temporary or otherwise, during all phases of construction.
- F-8. Protection barricades, when required, shall consist of a six foot (6') length of six inch (6") Schedule 40 black steel pipe filled with concrete and set in concrete to a depth of thirty-six inches (36") in a twelve inch (12") diameter hole. Barricades shall be placed thirty-six inches (36") apart unless otherwise noted. Barricades shall not obstruct the operation of the device being protected.
- F-9. When required, fire sprinkler underground mains to be constructed downstream of the fire sprinkler connection shall be sized by a licensed fire protection engineer or fire sprinkler contractor and installed pursuant to the requirements of the Fire Department. Fire sprinkler underground mains shown on these plans are not approved for construction. Fire sprinkler underground main plans shall be submitted under separate cover to the Fire Department for review and approval. Construction of water distribution facilities upstream of and including the fire sprinkler connection shall be constructed by a California Class "A" General Engineering Contractor pursuant to CHWD Note WS-1. The contractor shall confirm the Fire Department-approved size of the fire sprinkler connection prior to installation.