



NOTES:

- VALVE OPERATING HANDLE SHALL BE CENTERED IN BOX AND FULLY ACCESSIBLE.
- MATERIAL BELOW CRUSHED ROCK SHALL BE COMPACTED TO 95% MINIMUM.
- CONCRETE ENCASUREMENT SHALL BE ALLOWED TO CURE 24 HOURS MINIMUM PRIOR TO FINISH PAVING.
- LID SHALL BE MARKED "WATER"

		NON-TRAFFIC AREA	SIDEWALK/DW	STREET	5	3/4" CLEAN CRUSHED ROCK.
1	BOX	CARSON 1220-12	CHRISTY FL30TBOX12	CHRISTY B1324BOX	6	CONCRETE BRICK - 2 1/4" x 3 3/4" x 7 1/2"
2	LID	CARSON 1220-4B	CHRISTY FL30T	CHRISTY B1324-61JH	7	CONCRETE ENCASUREMENT AROUND VALVE BOX - TYPE II SIX-SACK PORTLAND CEMENT
3	#10 INSULATED COPPER LOCATOR WIRE					
4	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)					



**CITRUS
HEIGHTS
WATER
DISTRICT**

BLOW-OFF VALVE BOX

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Chubb

CITRUS HEIGHTS WATER DISTRICT

DATE: 5/8/13

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: VB_815.DWG

PAGE:

VB_815