



CARSON 1220-4B "T" TYPE LID:

SHALL INCLUDE STRAIGHT TYPE HEXAGON LOCK-DOWN BOLT (1) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

CHRISTY FL30P RECESSED LID:

SHALL INCLUDE STRAIGHT TYPE PENTAHEAD LOCK-DOWN BOLTS (2) AND NEPTUNE OFFSET AMR HOLE, SHALL BE MARKED "WATER"

METER YOKE:

FORD, JONES, MUELLER, McDONALD

1	3/4" BRONZE SADDLE - IPT	9	3/4" COPPER/BRASS METER YOKE - 12" HEIGHT w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET
2	3/4" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)	10	5/8" X 3/4" WATER METER (BY DISTRICT)
3	3/4" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SDDR 9 (250 PSI) OR EQUAL	11	PVC METER IDLER - 1' x 7 1/2", SCH 80 (BY CONTRACTOR)
4	3/4" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)	12	3/4" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
5	3/4" BRASS STREET ELBOW	13	3/4" PVC COUPLING - SCH 80
6	3/4" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)		NON-TRAFFIC AREAS
7	3/4" BRASS NIPPLE (AS NECESSARY TO ADJUST TO PROPER GRADE)	14	METER BOX
8	3/4" DUAL PURPOSE CONNECTION	15	LID
		16	2' x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
		17	3/4" CLEAN CRUSHED ROCK
		18	#2 WASHED SAND COMPACTED TO 90%
		19	#10 INSULATED COPPER LOCATOR WIRE

**3/4" POLYETHYLENE WATER SERVICE - 5/8" WATER METER
NEW CONSTRUCTION**

CITRUS HEIGHTS WATER DISTRICT



**CITRUS
HEIGHTS
WATER
DISTRICT**

APPROVED BY: *Melina Pieri*

CITRUS HEIGHTS WATER DISTRICT

DATE: APRIL 15, 2021

DRAWN: 25 SEP 2014

REVISED: 15 APR 2021

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_063PE.DWG

PAGE: **WS_063PE**