

CARSON 1220-4B "T" TYPE LID:
SHALL INCLUDE STRAIGHT TYPE HEXAGON
LOCK-DOWN BOLT (1) AND TOUCH READ HOLE.
SHALL BE MARKED "WATER"

CHRISTY FL30P RECESSED LID:

SHALL INCLUDE STRAIGHT TYPE PENTAHEAD
LOCK-DOWN BOLTS (2) AND NEPTUNE OFFSET
AMR HOLE, SHALL BE MARKED "WATER"

METER YOKE: FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	10	1" WATER METER (BY DISTRICT)				
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	11	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)				
3	1" COPPER TUBING - TYPE K SOFT	12	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)				
4	1" BRASS STREET ELBOW - CTS COMP x MIP	13	1" PVC COUPLING - SCH 80				
5	1" BRASS STREET ELBOW			NON-TRAFFIC AREAS	TRAFFIC AREAS		
6	1' VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP	14	METER BOX	CARSON 1220-12	CHRISTY FL30TB0X12		
7	1" BRASS or COPPER (AS NECESSARY TO ADJUST TO	15	LID	CARSON 1220-4B	CHRISTY FL30P		
PROPER GRADE)		16	2" x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)				
8	1" DUAL PURPOSE CONNECTION	17	3/4" CLEAN CRUSHED ROCK				
9	1" COPPER/BRASS METER YOKE - 12" HEIGHT		#2 WASHED SAND COMPACTED TO 90%				
	w/2 FULL-PORT ANGLE BALL VALVES						
	INCLUDING PADLOCK WINGS ON INLET AND OUTLET						
<u> </u>							



## 1" COPPER WATER SERVICE - 1" WATER METER NEW CONSTRUCTION

	CITRUS HEIGHTS WATER DISTRICT			DRAWN: 25 SEP 2014	
	CITROS IILIOITIS WA	REVISED: 15 APR 2021			
AF	APPRIVED BY: Melina Rieri		ADDII 45 0004	SCALE: N.T.S.	
	Traina Piero	DATE:	APRIL 15, 2021	DESIGN: P.A.D.	
	CITRUS HEIGHTS WATER DISTRICT			CAD FILE: WS_100CU.DWG	
				PAGE: WS_100CU	