



| | | | |
|---|---|---|---|
| 1 | 1' BRONZE SADDLE - IPT | 5 | 1' VALVE - FULL-PORT BALL, FIP x FIP or IPS COMP x FIP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52) |
| 2 | 1' CORPORATION STOP - FULL-PORT BALL, MIP x IPS COMP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52) | 6 | 1' BRASS STREET ELBOW |
| 3 | 1 1/4' POLYETHYLENE TUBING - CTS ENDPORRE PE-4710 SDDR 9 (250 PSI) OR EQUAL | 7 | #2 WASHED SAND COMPACTED TO 90% |
| 4 | 1' BRASS STREET ELBOW - IPS COMP x MIP w/ STAINLESS STEEL INSERT (1' CTS INSERT-52) | 8 | #10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX) |



**CITRUS
HEIGHTS
WATER
DISTRICT**

1 1/4" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE:

9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_128PE.DWG

PAGE:

WS_128PE