



1	1 1/2' BRONZE SADDLE - IPT	5	1 1/2' VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP
2	1 1/2' CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	6	1 1/2' BRASS STREET ELBOW
3	1 1/2' COPPER TUBING - TYPE K SOFT	7	#2 WASHED SAND COMPACTED TO 90%
4	1 1/2' BRASS STREET ELBOW - CTS COMP x MIP		



**CITRUS
HEIGHTS
WATER
DISTRICT**

1 1/2" COPPER WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: Robert A. Churchill DATE: 9/25/14
CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014
REVISED:
SCALE: N.T.S.
DESIGN: P.A.D.
CAD FILE: WS_158CU.DWG
PAGE: **WS_158CU**