



1	2" BRONZE SADDLE - IPT	5	2" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)
2	2" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)	6	2" BRASS STREET ELBOW
3	2" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SDDR 9 (250 PSI) OR EQUAL	7	#2 WASHED SAND COMPACTED TO 90%
4	2" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)	8	#10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX)



**CITRUS
HEIGHTS
WATER
DISTRICT**

2" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE: *9/25/14*

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_208PE.DWG

PAGE:

WS_208PE